

PWSID: Sejong Academy Program Code: HK Type:
System Name: 4215-07
City: St. Paul

Date Received: 03/09/23 10:20 Collector Name: Facility Staff
Rep. Temp. (°C): 16.2 Collector ID: None

MDH Sample Number: 23C0519-01

Location ID: 388980 Collect Date: 03/07/23 Field Residual Chlorine Result: None
Sampling Point: 3rd floor hallway Collect Time: 07:42 Field Fluoride Result: None
Matrix: Drinking Water Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 11:52	RCC	EPA 200.8	

MDH Sample Number: 23C0519-02

Location ID: 388981 Collect Date: 03/07/23 Field Residual Chlorine Result: None
Sampling Point: 3rd floor hallway Collect Time: 07:40 Field Fluoride Result: None
Matrix: Drinking Water Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 11:55	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

MDH Sample Number: 23C0519-03

Location ID: 388982	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 3rd floor hallway.	Collect Time: 07:41	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 11:57	RCC	EPA 200.8	

MDH Sample Number: 23C0519-04

Location ID: 388983	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 3rd floor SPED classroom.	Collect Time: 07:45	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:00	RCC	EPA 200.8	

MDH Sample Number: 23C0519-05

Location ID: 388984	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 2nd floor "Mother's Room".	Collect Time: 07:38	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:03	RCC	EPA 200.8	

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*

PWSID: Sejong Academy

MDH Sample Number: 23C0519-06

Location ID: 388985	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 2nd floor hallway.	Collect Time: 07:35	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:05	RCC	EPA 200.8	

MDH Sample Number: 23C0519-07

Location ID: 388986	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 2nd floor hallway	Collect Time: 07:34	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:08	RCC	EPA 200.8	

MDH Sample Number: 23C0519-08

Location ID: 388987	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 2nd floor hallway.	Collect Time: 07:36	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:16	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

MDH Sample Number: 23C0519-09

Location ID: 388988	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 1st floor hallway.	Collect Time: 07:21	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:18	RCC	EPA 200.8	

MDH Sample Number: 23C0519-10

Location ID: 388989	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 1st floor hallway.	Collect Time: 07:22	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:21	RCC	EPA 200.8	

MDH Sample Number: 23C0519-11

Location ID: 388990	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: 1st floor hallway.	Collect Time: 07:23	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:24	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

MDH Sample Number: 23C0519-12

Location ID: 388991	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Kindergarten classroom (#126, Lee)	Collect Time: 07:28	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:26	RCC	EPA 200.8	

MDH Sample Number: 23C0519-13

Location ID: 388992	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Kindergarten classroom (#126, Lee)	Collect Time: 07:27	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:29	RCC	EPA 200.8	

MDH Sample Number: 23C0519-14

Location ID: 388993	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Kindergarten classroom (#127,Beck)	Collect Time: 07:25	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:31	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

MDH Sample Number: 23C0519-15

Location ID: 388994	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Kindergarten classroom (#127,Beck)	Collect Time: 07:26	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:34	RCC	EPA 200.8	

MDH Sample Number: 23C0519-16

Location ID: 388995	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: PreK 121, McCormick	Collect Time: 07:31	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:37	RCC	EPA 200.8	

MDH Sample Number: 23C0519-17

Location ID: 388996	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: PreK 121, McCormick	Collect Time: 07:32	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0626	03/15/23 10:36	03/15/23 12:39	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

MDH Sample Number: 23C0519-18

Location ID: 388997
Sampling Point: PreK 120, Oh

Collect Date: 03/07/23
Collect Time: 07:30
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 12:58	RCC	EPA 200.8	

MDH Sample Number: 23C0519-19

Location ID: 388998
Sampling Point: PreK 120, Oh

Collect Date: 03/07/23
Collect Time: 07:29
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:06	RCC	EPA 200.8	

MDH Sample Number: 23C0519-20

Location ID: 388999
Sampling Point: Nurses' Office.

Collect Date: 03/07/23
Collect Time: 07:19
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:08	RCC	EPA 200.8	

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*

PWSID: Sejong Academy

MDH Sample Number: 23C0519-21

Location ID: 389000	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Teacher's Lounge	Collect Time: 07:18	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:11	RCC	EPA 200.8	

MDH Sample Number: 23C0519-22

Location ID: 389001	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Kitchen	Collect Time: 07:10	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:13	RCC	EPA 200.8	

MDH Sample Number: 23C0519-23

Location ID: 389002	Collect Date: 03/07/23	Field Residual Chlorine Result: None
Sampling Point: Lower level hallway.	Collect Time: 07:11	Field Fluoride Result: None
	Matrix: Drinking Water	Field pH Result: None
		Field PO ₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:16	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
 This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
 Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

MDH Sample Number: 23C0519-24

Location ID: 389003
Sampling Point: Lower level hallway

Collect Date: 03/07/23
Collect Time: 07:12
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:19	RCC	EPA 200.8	

MDH Sample Number: 23C0519-25

Location ID: 389004
Sampling Point: Lower level hallway.

Collect Date: 03/07/23
Collect Time: 07:13
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:21	RCC	EPA 200.8	

MDH Sample Number: 23C0519-26

Location ID: 389005
Sampling Point: Science Lab 026, Oh

Collect Date: 03/07/23
Collect Time: 07:16
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:24	RCC	EPA 200.8	

Authorized by:



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*

PWSID: Sejong Academy

MDH Sample Number: 23C0519-27

Location ID: 389006
Sampling Point: Science Lab 024, Kwok

Collect Date: 03/07/23
Collect Time: 07:15
Matrix: Drinking Water

Field Residual Chlorine Result: None
Field Fluoride Result: None
Field pH Result: None
Field PO₄ Result: None

Results were produced by the Minnesota Department of Health, except where noted.

Metal Parameters

Analyte	Result	Reporting Limit	Units	Batch	Prepared	Analyzed	Init.	Method	Qualifiers
Lead	<	1.00	ug/L	B3C0627	03/15/23 10:38	03/15/23 13:27	RCC	EPA 200.8	

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

Results were produced by Minnesota Department of Health, except where noted.

Batch B3C0626 - EPA 200 Series Prep

Blank (B3C0626-BLK1)

Prepared: 03/15/23 10:36 Analyzed: 03/15/23 11:34

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B3C0626-BS1)

Prepared: 03/15/23 10:36 Analyzed: 03/15/23 11:36

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.7		ug/L	50		97	85-115			RCC	

Duplicate (B3C0626-DUP1)

Source: 23C0421-01

Prepared: 03/15/23 10:36 Analyzed: 03/15/23 11:42

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Duplicate (B3C0626-DUP2)

Source: 23C0519-17

Prepared: 03/15/23 10:36 Analyzed: 03/15/23 12:42

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Matrix Spike (B3C0626-MS1)

Source: 23C0421-01

Prepared: 03/15/23 10:36 Analyzed: 03/15/23 11:44

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.6		ug/L	50		97	70-130			RCC	

Matrix Spike (B3C0626-MS2)

Source: 23C0519-17

Prepared: 03/15/23 10:36 Analyzed: 03/15/23 12:45

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	45.6		ug/L	50		91	70-130			RCC	

Batch B3C0627 - EPA 200 Series Prep

FINAL REPORT

Report ID: 03202023113211

Generated: 3/20/2023 11:31:54AM

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health

PWSID: Sejong Academy

Results were produced by Minnesota Department of Health, except where noted.

Batch B3C0627 - EPA 200 Series Prep

Blank (B3C0627-BLK1)

Prepared: 03/15/23 10:38 Analyzed: 03/15/23 12:52

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L							RCC	

LCS (B3C0627-BS1)

Prepared: 03/15/23 10:38 Analyzed: 03/15/23 12:55

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.8		ug/L	50		98	85-115			RCC	

Duplicate (B3C0627-DUP1)

Source: 23C0519-18

Prepared: 03/15/23 10:38 Analyzed: 03/15/23 13:00

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	<	1.00	ug/L		<				20	RCC	

Matrix Spike (B3C0627-MS1)

Source: 23C0519-18

Prepared: 03/15/23 10:38 Analyzed: 03/15/23 13:03

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Init.	Qualifiers
Lead	48.6		ug/L	50		97	70-130			RCC	

Work Order Comments

Samples were received in proper condition.

Authorized by:

*The results in this report apply only to the samples analyzed.
This report must not be reproduced, except in full, without the written approval of the laboratory.*



Stefan Saravia, Environmental Laboratory Manager
Public Health Laboratory, Minnesota Department of Health